

POOL/SPA DAILY MAINTENANCE LOG

CA Code of Regulations, Title 22, Section 65523:

- (a) The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant (e.g., chlorine) residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used.
- (b) If cyanuric acid is added to a pool, the concentration shall be measured a minimum of once per month and records shall be kept of the results.
- (c) Data collected pursuant to subsections (a) and (b) shall be maintained at least one year for inspection by the enforcing agent, or shall be submitted to the enforcing agent upon request.

MONTH: _____

DATE	CHLORINE RESIDUAL	pH	OTHER MAINTENANCE
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			

Monthly Cyanuric Acid (i.e., stabilizer/conditioner)
 Reading: _____ Should not exceed 100 ppm (ideally 20-50ppm)

Reminder:
 - pH: 7.2 - 8.0 (ideally 7.4 - 7.6)
 - Chlorine: minimum 1.5 ppm w/ cyanuric acid / 1.0 ppm w/o cyanuric acid